

**SHERIDAN AREA WATER SUPPLY JOINT POWERS BOARD
RULES AND REGULATIONS
FOR
NEW WATER MAIN EXTENSIONS TO SERVE NEW DEVELOPMENT**

4. **Extension of Water System**

...Every proposed Subdivision, Planned Unit Development (“PUD”), or water main extension applicants shall apply for and secure a final written Water Service Agreement acceptable to the Administrator and approved by the Board before any taps may be committed to any Customer or User whose lands are located within such developments.

16. Sanitary Regulations

b. All newly constructed mains shall be a minimum diameter of 4-inches and shall otherwise conform to these Rules and shall conform to the applicable requirements of the City of Sheridan, the State of Wyoming Department of Environmental Quality – Water Quality Division, Sheridan County and the Administrator. In the event that SAWSJPB requires an Applicant or User to install a water main larger than 8-inch diameter, and the larger-sized water main is not required for said development, SAWSJPB may choose, in its discretion, to reimburse the Applicant or User for the actual materials cost difference between the “oversized” main and an 8-inch main.

c. All service lines or pipes through which water supplied by SAWSJPB shall be installed in accordance with all: (1) relevant Plumbing Codes adopted by the City of Sheridan; (2) relevant City of Sheridan Standard Specifications for Street and Utility Construction; (3) relevant State of Wyoming Department of Environmental Quality - Water Quality Rules and Regulations; and, (4) relevant Sheridan County, Wyoming, building and plumbing standards. All pipe work that will connect to the SAWSJPB water system that is located within public and/or private property shall be available for inspection by the Administrator or his authorized representative during construction and thereafter by exposing such works at the applicant or user’s expense. Any unsatisfactory work or exceptions shall be corrected by the Applicant or User. An appropriate cross-connection control device shall be installed on each service line consistent with current City of Sheridan Ordinance No. 1946, as amended, or any equivalent City of Sheridan Ordinance or requirement.

Within sixty (60) days immediately following the provision of water service in such lines and facilities, all Applicants who install any service pipes and/or facilities which connect to the SAWSJPB system shall provide the Administrator with complete and accurate “AS-BUILT” accurate drawings showing the installed location of all service line and facility installations.

At its May 9, 2018 Regular Meeting, the SAWSJPB adopted the “SAWSJPB Development and Permitting Procedure” which will govern the development of all new proposed developments to the SAWSJPB water system.